



**PLAN VIEW**  
NOT TO SCALE

MODEL : SFDD-  
 NET OPENING :  
 UNITS REQUIRED :  
 DOME COLOR :  
 FINISH :

**SECTION A-A = SELF - FLASHING DOME (SFDD)**

SCALE : 1/2" = 1"

**SPECIFICATIONS:**

UNIT SHALL BE CONSTRUCTED OF 6063-T5 ALUMINUM EXTRUSION HAVING MINIMUM WALL THICKNESS OF .063. UNIT SHALL BE NEATLY FORMED AND FABRICATED WITH ALL JOINTS AND SEAMS COMPLETELY WELDED BY HELI-ARC PROCESS TO ENSURE MAXIMUM STRENGTH AND WATER TIGHTNESS. ACRYLIC PLASTIC DOME SHALL BE OF A THICKNESS AND CONFIGURATION TO CONFORM WITH U.B.C. REQUIREMENTS AND AAMA SPECIFICATIONS. UNIT SHALL BE SUPPLIED TO JOB READY FOR INSTALLATION.

CALIFORNIA STATE FIRE MARSHALL APPROVAL NO. 4350-054  
 SEE I.C.B.O. ES APPROVAL NO. 1998  
 CITY OF LOS ANGELES RESEARCH REPORT NO. RR-2708

 <b>INDUSTRIAL</b> <i>By</i> <b>LADDER &amp; SCAFFOLDING</b> <i>Lane-Aire</i> <small>8152 BELVEDERE AVE. SACRAMENTO, CA (916)452-0231</small>	
JOB	SHEET
ARCH.	OF
CONTR.	DWG. NO.
SUB. CONTR.	
DRAWN BY	DATE:
	REC.